

# Pegler Valve

DZR ball valve with tee - full bore. Tectite push-fit ends for copper, carbon and stainless steel tube



## **General Information**

Size	Pattern No.	Pack 1 Qty	Pack 2 Qty	Code	Barcode	Price (£) each ex VAT
15mm l	PT550T	1	10	<u>245250</u> <b>5</b>	02205056159	6 £34.52
22mm l	PT550T	1	10	<u>245252</u> <b>5</b>	02205056168	8 £43.99

## **Pressure and Temperature**

Description	Minimum Operating Pressure (bar)	Maximum Cold Working Pressure (bar)	Maximum Hot Working Pressure (bar)
PT550T Ball valve	No minimum operating pressure.	15-28mm 20 bar up to 30oC 35-54mm 16 bar up to 30oC	15-28mm 10 bar up to 114oC 35-54mm 6 bar up to 90oC

## **Care and Maintenance**

#### Care

No regular aesthetic care is required for this product

#### Maintenance

A regular maintenance program is the most efficient method of ensuring longer term operational efficiency of the selected valve. Such a program would need to include a risk assessment and a planned procedure of how the maintenance will be carried out. The possibility of operational limits being exceeded and the potential hazards ensuring must be considered as part of this assessment. This should be implemented to include visual checks on the valve's condition and any development of unforeseen conditions, which could lead to failure. The correct fitting tools and equipment should be used for valve maintenance work. Separate means of draining the pipe work must be provided when carrying out any maintenance to valves. Where there may be any system debris this could be collected and /or filtered by installation of the appropriate protective device.

For further help please contact your local engineer.

If your product is under warranty please contact the Service Support Team on: 0800 1560050

#### Regulations

#### Regulations

#### THE PRESSURE EQUIPMENT DIRECTIVE 97/23/EC and CE MARKING

The Pressure Equipment Regulations 1999 (SI 1999/2001) have now been introduced into United Kingdom law

Valves with a maximum allowable pressure greater than 0.5 bar are covered by these new Regulations. Valves are categorised according to their maximum working pressure, size and rising level of hazard. The level of hazard varies according to the fluid being carried. Fluids are classified as Group 1, dangerous fluids or Group 2, all other fluids including steam. The Categories designated are SEP (sound engineering practice). Valves up to and including 25mm (1") are designated SEP regardless of the fluid group. Those identified as having increased hazard are Categorised as, I, II, III or IV. All valves designated as SEP do not bear the CE mark nor require a Declaration of Conformity. Categories I, II, III or IV carry the CE mark and require a Declaration of Conformity. Valves classified from the piping chart would not be included in Category IV.

# Size Pattern No. Code PED Categorisation

15mm PT550T 245250 SEP 22mm PT550T 245252 SEP

# **Materials**

Component	Material
Body	DZR Brass
Ball	Brass, chrome plated
Seat/thrust washer	PTFE (Teflon)
Stem 'O' ring	Viton
Lever handle	High temperature PVC insulated
Nut (self locking)	Zinc plated steel
Tee handle	Aluminium, painted
Security screws	Nickel plated brass
Stem	DZR Brass
End connection	DZR Brass body (15 to 54) (15 to 28)
End connection 'O' ring	EPDM (15 to 54) (15 to 28)
Grab ring	Stainless steel SS316 (15 to 54) (15 to 28)
Sleeve	Brass (EL)
Ext Stem	Brass (EL)
Fixing screw	Steel (EL)
Washer	Brass (EL)

Pegler Yorkshire Group Ltd, St Catherine's Ave, Doncaster, S Yorkshire, DN4 8DF
Telephone: Phone +44 (0) 844 243 4400 Fax: +44 (0) 844 243 9870 Website: www.pegleryorkshire.co.uk
Registered office: Pegler Yorkshire Group Ltd, St Catherine's Ave, Doncaster, S Yorkshire, DN4 8DF Company no: 00401507